



DC Prep PCS (Anacostia) - Lead in Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
DC Prep PCS [Anacostia]	WS-113-001	Food Prep Sink	Basement	In kitchen	-	Left	WF-112017-113001-01	5/21/18	FT-FY18-112017-113001	3.2	<1
DC Prep PCS [Anacostia]	WS-113-002	Food Prep Sink	Basement	In kitchen	-	Right	WF-112017-113002-01	5/21/18	FT-FY18-112017-113002	1.0	<1
DC Prep PCS [Anacostia]	WS-113-003	Health Suite	1	In health suite 104	-	-	WF-102017-113003-01	5/21/18	FT-FY18-102017-113003	<1	<1
DC Prep PCS [Anacostia]	WS-113-004	Break Room	3	In break room 301	-	-	WF-102017-113004-01	5/21/18	FT-FY18-102017-113004	<1	<1
DC Prep PCS [Anacostia]	WS-113-005	Break Room	3	In lactation room 310	-	-	WF-102017-113005-01	5/21/18	FT-FY18-102017-113005	<1	<1
DC Prep PCS [Anacostia]	WS-113-006	Cooler	Ground	In hallway adjacent to room 009	High	Left	WF-102017-113006-01	5/21/18	FT-FY18-102017-113006	<1	<1
DC Prep PCS [Anacostia]	WS-113-007	Cooler	Ground	In hallway adjacent to room 009	Low	Right	WF-102017-113007-01	5/21/18	FT-FY18-102017-113007	<1	<1
DC Prep PCS [Anacostia]	WS-113-008	Cooler	1	In hallway adjacent to room 124	High	Left	WF-102017-113008-01	5/21/18	FT-FY18-102017-113008	<1	<1
DC Prep PCS [Anacostia]	WS-113-009	Cooler	1	In hallway adjacent to room 124	Low	Right	WF-102017-113009-01	5/21/18	FT-FY18-102017-113009	<1	<1
DC Prep PCS [Anacostia]	WS-113-010	Cooler	1	In hallway adjacent to gym 131	High	Left	WF-102017-113010-01	5/21/18	FT-FY18-102017-113010	<1	<1
DC Prep PCS [Anacostia]	WS-113-011	Cooler	1	In hallway adjacent to gym 131	Low	Right	WF-102017-113011-01	5/21/18	FT-FY18-102017-113011	<1	<1
DC Prep PCS [Anacostia]	WS-113-012	Cooler	2	In hallway adjacent to room 209	High	Left	WF-102017-113012-01	5/21/18	FT-FY18-102017-113012	<1	<1
DC Prep PCS [Anacostia]	WS-113-013	Cooler	2	In hallway adjacent to room 209	Low	Right	WF-102017-113013-01	5/21/18	FT-FY18-102017-113013	<1	<1