



DC Prep PCS (Benning - Elementary School) - Lead in Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
DC Prep PCS [Benning - Elementary School]	WS-095-001	Cooler	1	In hallway adjacent to 108	-	-	WF-112017-095001-01	5/22/18	FT-FY18-112017-095001	<1	<1
DC Prep PCS [Benning - Elementary School]	WS-095-003	Cooler	1	In hallway adjacent to room 139	-	-	WF-112017-095003-01	5/22/18	FT-FY18-112017-095003	<1	<1
DC Prep PCS [Benning - Elementary School]	WS-095-004	Cooler	1	In hallway adjacent to room 159	-	-	WF-112017-095004-01	5/22/18	FT-FY18-112017-095004	<1	<1
DC Prep PCS [Benning - Elementary School]	WS-095-005	Cooler	2	In hallway adjacent to room 235	-	-	WF-112017-095005-01	5/22/18	FT-FY18-112017-095005	<1	<1
DC Prep PCS [Benning - Elementary School]	WS-095-006	Cooler	2	In hallway across from room 234	-	-	WF-112017-095006-01	5/22/18	FT-FY18-112017-095006	<1	<1
DC Prep PCS [Benning - Elementary School]	WS-095-007	Break Room	2	In staff lounge 217	-	-	WF-112017-095007-01	5/22/18	FT-FY18-112017-095007	1.3	<1
DC Prep PCS [Benning - Elementary School]	WS-095-008	Cooler	2	In hallway adjacent to room 216	-	-	WF-112017-095008-01	5/22/18	FT-FY18-112017-095008	<1	<1
DC Prep PCS [Benning - Elementary School]	WS-095-009	Cooler	2	In hallway across from room 208	-	-	WF-112017-095009-01	5/22/18	FT-FY18-112017-095009	<1	<1



DC Prep PCS (Benning - Middle School) - Lead in Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
DC Prep PCS [Benning - Middle School]	WS-096-001	Health Suite	1	In health suite 168	-	-	WF-112017-096001-01	5/20/18	FT-FY18-112017-096001	<1	<1
DC Prep PCS [Benning - Middle School]	WS-096-002	Break Room	1	In staff lounge 170	-	-	WF-112017-096002-01	5/20/18	FT-FY18-112017-096002	<1	<1
DC Prep PCS [Benning - Middle School]	WS-096-003	Cooler	1	In hallway across from room 200	High	Left	WF-112017-096003-01	5/20/18	FT-FY18-112017-096003	<1	<1
DC Prep PCS [Benning - Middle School]	WS-096-004	Cooler	1	In hallway across from room 200	Low	Right	WF-112017-096004-01	5/20/18	FT-FY18-112017-096004	<1	<1
DC Prep PCS [Benning - Middle School]	WS-096-005	Cooler	2	In hallway across from room 282A	High	Left	WF-112017-096005-01	5/20/18	FT-FY18-112017-096005	<1	<1
DC Prep PCS [Benning - Middle School]	WS-096-006	Cooler	2	In hallway across from room 282A	Low	Right	WF-112017-096006-01	5/20/18	FT-FY18-112017-096006	<1	<1