



DC Prep PCS (Edgewood Elementary) - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

| Charter Campus Name | Water Source ID | Device Type | Floor | Device Location | Location Identifier | | Water Filter ID | Date Analyzed | Draw A Sample ID | FT Final Results - Draw A (ppb) | Draw B Sample ID | FT Final Results - Draw B (ppb) |
|--|-----------------|--------------|-------|---------------------------------|---------------------|----------------|---------------------|---------------|-------------------------|---------------------------------|-------------------------|---------------------------------|
| | | | | | High/Low | Left/Mid/Right | | | | | | |
| DC Prep PCS [Edgewood - Elementary School] | WS-058-002 | Cooler | 1 | In hallway across from room 107 | High | Left | WF-082019-058002-02 | 10/24/2019 | FT-FY20-082019-058002-A | <1 | FT-FY20-082019-058002-B | <1 |
| DC Prep PCS [Edgewood - Elementary School] | WS-058-003 | Cooler | 1 | In hallway across from room 107 | Low | Right | WF-082019-058003-02 | 10/24/2019 | FT-FY20-082019-058003-A | <1 | FT-FY20-082019-058003-B | <1 |
| DC Prep PCS [Edgewood - Elementary School] | WS-058-004 | Break Room | 2 | In breakroom 205 | | | WF-082019-058004-02 | 10/24/2019 | FT-FY20-082019-058004-A | <1 | FT-FY20-082019-058004-B | <1 |
| DC Prep PCS [Edgewood - Elementary School] | WS-058-005 | Cooler | 2 | In hallway across from room 204 | High | Left | WF-082019-058005-02 | 10/24/2019 | FT-FY20-082019-058005-A | <1 | FT-FY20-082019-058005-B | <1 |
| DC Prep PCS [Edgewood - Elementary School] | WS-058-006 | Cooler | 2 | In hallway across from room 204 | Low | Right | WF-082019-058006-02 | 10/24/2019 | FT-FY20-082019-058006-A | <1 | FT-FY20-082019-058006-B | <1 |
| DC Prep PCS [Edgewood - Elementary School] | WS-058-007 | Break Room | 2 | In breakroom 201 | | | WF-082019-058007-02 | 10/24/2019 | FT-FY20-082019-058007-A | <1 | FT-FY20-082019-058007-B | <1 |
| DC Prep PCS [Edgewood - Elementary School] | WS-058-008 | Health Suite | 1 | In health suite 119 | | | WF-082019-058008-02 | 10/24/2019 | FT-FY20-082019-058008-A | 1.3 | FT-FY20-082019-058008-B | <1 |