



DC Prep PCS (Anacostia) - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
DC Prep PCS [Anacostia]	WS-113-001	Food Prep Sink	Basement	In kitchen		Left	WF-072019-113001-02	12/31/2019	FT-FY20-072019-113001-A	1.3	FT-FY20-072019-113001-B	<1
DC Prep PCS [Anacostia]	WS-113-002	Food Prep Sink	Basement	In kitchen		Right	WF-072019-113002-02	12/31/2019	FT-FY20-072019-113002-A	1.1	FT-FY20-072019-113002-B	<1
DC Prep PCS [Anacostia]	WS-113-003	Health Suite	1	In health suite 104			WF-072019-113003-02	12/31/2019	FT-FY20-072019-113003-A	<1	FT-FY20-072019-113003-B	<1
DC Prep PCS [Anacostia]	WS-113-004	Break Room	3	In break room 301			WF-072019-113004-02	12/31/2019	FT-FY20-072019-113004-A	<1	FT-FY20-072019-113004-B	<1
DC Prep PCS [Anacostia]	WS-113-005	Break Room	3	In lactation room 310			WF-072019-113005-02	12/31/2019	FT-FY20-072019-113005-A	<1	FT-FY20-072019-113005-B	<1
DC Prep PCS [Anacostia]	WS-113-006	Cooler	Ground	In hallway adjacent to room 009	High	Left	WF-112019-113006-03	12/31/2019	FT-FY20-112019-113006-A	<1	FT-FY20-112019-113006-B	<1
DC Prep PCS [Anacostia]	WS-113-007	Cooler	Ground	In hallway adjacent to room 009	Low	Right	WF-112019-113007-03	12/31/2019	FT-FY20-112019-113007-A	<1	FT-FY20-112019-113007-B	<1
DC Prep PCS [Anacostia]	WS-113-008	Cooler	1	In hallway adjacent to room 124	High	Left	WF-112019-113008-03	12/31/2019	FT-FY20-112019-113008-A	<1	FT-FY20-112019-113008-B	<1
DC Prep PCS [Anacostia]	WS-113-009	Cooler	1	In hallway adjacent to room 124	Low	Right	WF-112019-113009-03	12/31/2019	FT-FY20-112019-113009-A	<1	FT-FY20-112019-113009-B	<1
DC Prep PCS [Anacostia]	WS-113-010	Cooler	1	In hallway adjacent to gym 131	High	Left	WF-072019-113010-02	12/31/2019	FT-FY20-072019-113010-A	<1	FT-FY20-072019-113010-B	<1
DC Prep PCS [Anacostia]	WS-113-011	Cooler	1	In hallway adjacent to gym 131	Low	Right	WF-072019-113011-02	12/31/2019	FT-FY20-072019-113011-A	<1	FT-FY20-072019-113011-B	<1
DC Prep PCS [Anacostia]	WS-113-012	Cooler	2	In hallway adjacent to room 209	High	Left	WF-112019-113012-03	12/31/2019	FT-FY20-112019-113012-A	<1	FT-FY20-112019-113012-B	<1
DC Prep PCS [Anacostia]	WS-113-013	Cooler	2	In hallway adjacent to room 209	Low	Right	WF-112019-113013-03	12/31/2019	FT-FY20-112019-113013-A	<1	FT-FY20-112019-113013-B	<1